



DETAIL PROTECTION




- TRIFLEX CRYL FINISH 209 (THIXO IF VERTICAL > 250mm) @ 0.50 Kg/m² MIN.
- TRIFLEX PRODETAIL® @ 3.00 Kg/m² MIN.
- TRIFLEX 110g REINFORCEMENT FLEECE
- TRIFLEX PRIMER (REFER TO PROJECT SPECIFICATION PROPOSAL)
- GENERIC SUBSTRATE (PREPARED)

MAIN AREA WATERPROOFING



- TRIFLEX CRYL FINISH 202 @ 0.80 Kg/m² MIN.
- TRIFLEX DECKFLOOR RS THIXO (BLACK) @ 4.50 Kg/m² MIN. WITH TRIFLEX EMERY (1.0 - 3.0mm) @ 6.00 Kg/m² APPROX.
- TRIFLEX PROPARK® @ 3.00 Kg/m² MIN.
- TRIFLEX 110g REINFORCEMENT FLEECE
- TRIFLEX PRIMER (REFER TO PROJECT SPECIFICATION PROPOSAL)
- GENERIC DIMENSIONALLY STABLE / SUITABLE SUBSTRATE (PREPARED)




GENERAL NOTES

This drawing and any reference to structural / thermal elements should be treated as indicative only and read in conjunction with the Triflex Project specification proposal and relevant Triflex technical data. Details should be verified for accuracy and suitability as we specifically exclude any liability for errors, omissions or otherwise.

The drawing should not be reproduced or amended except with the written permission of Triflex. Do not scale, use figured dimensions only, and check all dimensions on site.

INDICATIVE SYSTEM BUILD-UP



SYSTEM

TRIFLEX PROPARK HD RAMP WITH EMERY 1.0-3.0mm

PROJECT

STANDARD

DETAIL

PENETRATION - FULL UPSTAND

DRAWING NUMBER

PROPARK HD RAMP_052
_PENETRATION - FULL
UPSTAND

SCALE

NTS

DATE


10/08/2018

Triflex

Delivering solutions together.

Triflex (UK) Limited

Whitebridge Way | Stone | Staffs
ST15 8JS | Tel: 01785 819119
www.triflex.co.uk | info@triflex.co.uk



CAR PARK | MARKINGS | REPAIRS